



**NOTES:**

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 48 HOURS IN ADVANCE.
2. IF THE REQUIRED SAFETY CLEARANCE AROUND A SWITCH OR TRANSFORMER ABUTS A SOLID OBSTRUCTION, THE SAFETY CLEARANCES SHALL BE INCREASED BY 2 FEET.

					<b>BURBANK WATER AND POWER – ELECTRIC SERVICES</b>	
B	ADDED NOTE 2	MEP	SK		9/26/23	DRAWING No.
A	STANDARDIZED FORMATTING/UPDATE CLEARANCES	MEP	CJC	5/9/23	SWITCH & (2) TRANSFORMER PADS	
	NEW DRAWING	MJK	GLS	8/22/96	REQUIRED CLEARANCES	
No.	REVISIONS	BY	APPR'V'D	DATE	ORIENTATION PLAN NO. 1	
						<b>S-603B</b>
						Sheet 1 of 1