


**NOTES:**

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 48 HOURS IN ADVANCE.
2. IF THE REQUIRED SAFETY CLEARANCE AROUND A SWITCH OR TRANSFORMER ABUTS A SOLID OBSTRUCTION, THE SAFETY CLEARANCES SHALL BE INCREASED BY 2 FEET.

					<b>CITY OF BURBANK</b>		<b>BURBANK WATER AND POWER – ELECTRIC SERVICES</b>			
B	ADDED NOTE 2	MEP	SK	9/26/23		<b>SWITCH &amp; (2) TRANSFORMER PADS REQUIRED CLEARANCES ORIENTATION PLAN No. 4</b>		DRAWING No.		
A	STANDARDIZED FORMATTING/UPDATE CLEARANCES	MEP	CJC	5/9/23				<b>WATER AND POWER</b>	<b>S-606B</b>	
	NEW DRAWING	MJK	GLS	8/23/96					Sheet 1 of 1	
No.	REVISIONS	BY	APPR'V'D	DATE						