


**NOTE:**

FOR SAFETY PURPOSES, WHEN PROPOSED CONSTRUCTION PLANS PLACE THE NEW STRUCTURE IN CLOSE PROXIMITY TO THE PRIMARY AND SECONDARY OVERHEAD CONDUCTORS, THEN THE DESIGNER MUST REVISE THE PLANS TO AVOID ENCROACHMENT INTO THE BUILDING ENVELOPE CLEARANCE AREA SHOWN BELOW. BUILDING ELEVATIONS MUST BE PROVIDED TO SHOW LOCATIONS OF THE EXISTING POWER POLE(S), THEIR HEIGHT(S) FROM NATURAL GRADE, CONDUCTOR ATTACHMENT HEIGHTS, THE LOWEST POINT OF THE CONDUCTOR'S SAG, (ALL SURVEYED), AND ALL PERTINENT CLEARANCE DIMENSIONS TO SHOW THAT ALL PORTIONS OF THE BUILDING ARE OUTSIDE OF THIS CLEARANCE ZONE.

NO PERMANENT STRUCTURE IS TO BE BUILT WITHIN THE UTILITIES EASEMENT AND/OR BELOW ANY PRIMARY CONDUCTOR'S DRIP LINE.

NO OPEN PATIOS OR BALCONIES WILL BE ERECTED UNDERNEATH ANY HIGH VOLTAGE OVERHEAD CONDUCTORS, REGARDLESS OF VERTICAL CLEARANCE.

IF TEMPORARY SCAFFOLDING, PLATFORMS, OR SUPPORTING STRUCTURES UPON WHICH MEN MAY WORK SHALL ENTER THE BUILDING ENVELOPE CLEARANCE, DURING CONSTRUCTION, OR IF AERIAL TRUCK ACCESS IS TO PLACE WORKER(S) WITHIN A MINIMUM OF TEN FEET OF THE PRIMARY HIGH VOLTAGE CONDUCTORS (UP TO 12KV), THEN BWP SHALL INSTALL PRIMARY HARD COVERS TO THE PERTINENT AREA OF HIGH VOLTAGE CONDUCTORS AND EXPOSED EQUIPMENT AT THE OWNER'S EXPENSE, PRIOR TO ANY WORK BEING PERFORMED IN THAT AREA. PLANS MUST SHOW PROOF OF SCAFFOLDING OR OTHER SUPPORT STRUCTURES OUTSIDE OF THE CLEARANCE ZONE IN ORDER TO AVOID THE NECESSITY OF BWP HAVING TO COVER THE HIGH VOLTAGE LINES. ANY PROPOSED ENCROACHMENT OF MEN WORKING WITHIN 10 FEET OF PRIMARY HIGH VOLTAGE LINES OF 34.5KV OR 69KV WILL REQUIRE THE CONDUCTORS TO BE DE-ENERGIZED AND GROUNDED BY THE UTILITY, PRIOR TO THE ENCROACHMENT, AT THE OWNER'S EXPENSE.



B	STANDARDIZED FORMATTING	MEP	CJC	5/9/23
A	ADD NOTES / DIMENSIONS	SRA	RS	6/6/18
No.	REVISIONS	BY	APPR'V'D	DATE



BURBANK WATER AND POWER – ELECTRIC SERVICES

DRAWING No.  
**S-708B**

G.O. 95  
 CLEARANCES

Sheet 1 of 1