


- TO BE CONSIDERED LADDER ACCESSIBLE:
1. DISTANCE A MUST BE NO GREATER THAN 23' FROM FINAL EXTERIOR GRADE.
 2. DISTANCE B MUST BE NO LESS THAN A/4.
 3. DISTANCE C MUST BE NO GREATER THAN 18".

A	B
23'	5.75'
22'	5.5'
21'	5.25'
20'	5'
19'	4.75'
18'	4.50'
17'	4.25'
16'	4'



- NOTES:**
1. BWP PERSONNEL WILL NOT ACCESS ROOF WITH MORE THAN 4:12 PITCH, OR ANY ROOF MADE OF FRAGILE MATERIAL, SUCH AS TILE, WOOD SHINGLE, ETC.
 2. ALL CONNECTIONS MUST BE WORKABLE FROM LADDER PER THE ABOVE RESTRICTIONS.
 3. ROOF HEIGHTS THAT WOULD PUT THE RISER HEIGHT ABOVE 23' WILL REQUIRE AN UNDER EAVES ATTACHMENT PER BWP DRAWINGS S-727 OR S-0816.

						BURBANK WATER AND POWER – ELECTRIC SERVICES	
						DRAWING No.	
B	STANDARDIZED FORMATTING	MEP	CJC	5/9/23	<p style="text-align: center;">LADDER ACCESSIBILITY</p>		S-714B
A	REVISE NOTES AND DIAGRAM	SRA	RS	6/8/19			Sheet 1 of 1
No.	REVISIONS	BY	APPR'V'D	DATE	WATER AND POWER		