

**BURBANK WATER AND POWER  
2016 RECYCLED WATER SAMPLING RESULTS**

			2016						6 Month Avg.	2016 Potable
			Mar	Apr	May	Jun	Jul	Aug		
Turbidity	avg.	NTU	0.23	0.25	0.22	0.22	0.58	0.48	0.33	0.064
pH	min.	S.U.	7.3	6.9	6.8	6.8	7.0	6.6	6.9	8.2
pH	max.	S.U.	7.8	7.5	7.7	7.7	7.6	7.6	7.7	8.3
TSS	avg.	mg/l	<1	<1	1	1	1	1	<1	
BOD	avg.	mg/l	<3	<3	<3	<3	<3	<3	<3	
TDS	max.	mg/l	668	795	710	730	860	690	742	495
Chloride	max.	mg/l	132	150	140	130	130	130	135	61
Sulfate	max.	mg/l	140	197	150	140	140	140	151	93
Fluoride	max.	mg/l	0.72	0.71	0.71	0.69	0.66	0.67	0.69	0.54
Hardness	max.	mg/l	276	254	278	269	251	257	264	275
Boron	max.	mg/l	0.39	0.36	0.52	0.36	0.42	0.52	0.43	0.12
Nitrate-N	max.	mg/l	6.5	6.8	7.2	8.2	9.5	7.5	7.6	6.4
Nitrite-N	max.	mg/l	0.8	0.7	0.5	0.3	0.3	0.4	<0.1	<0.2
Nitrate+Nitrite	max.	mg/l	7.3	7.5	7.7	8.6	9.8	7.9	8.1	6.4
Ammonia-N	max.	mg/l	1.0	0.9	0.9	0.8	0.8	1.0	0.9	
Phosphorus-P	max.	mg/l	4.3	1.8	4.7	2.6	2.9	0.7	2.8	
Phosphate (PO4)	max.	mg/l	13	6	14	8	9	2	8.6	1.2
Alkalinity(CaCO3)	max.	mg/l	190	180	210	220	200	210	202	185
Bicarbonate(HCO3)	max.	mg/l	240	210	250	270	250	250	245	225
Conductivity	max.	umho/cm	1000	750	1200	1100	1100	1100	1042	765
Aluminum	max.	µg/l	ND	ND	ND	ND	ND	ND	ND	32
Arsenic	max.	µg/l	1.6	1.3	1.5	1.4	1.7	1.2	1.5	<1
Cadmium	max.	µg/l	0.1	0.1	0.2	0.1	0.1	0.1	0.13	<0.50
Chromium	max.	µg/l			4.2			2.4	3.3	4
Cobalt	max.	µg/l	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<2
Copper	max.	µg/l	10	9	14	11	8	9	10	<2
Iron	max.	µg/l	65	36	21	26	51	56	43	<20
Lead	max.	µg/l	<0.048	0.5	1.3	0.4	0.7	0.9	0.7	<0.50
Manganese	max.	µg/l			2.5			3.2	3	<2
Mercury	max.	µg/l			<2			<2	<0.2	<0.20
Nickel	max.	µg/l	<5	<5	8.3	5.3	<5	<5	<5	<5
Selenium	max.	µg/l			3.1			2.2	3	<5
Zinc	max.	µg/l	75	71	80	74	70	67	73	<20
Beryllium	max.	µg/l	<1	<1	<1	<1	<1	<1	<1	<1
Calcium	max.	mg/l	64	71	72	76	70	69	70	74
Magnesium	max.	mg/l	20	22	23	23	22	22	22	22
Potassium	max.	mg/l	17	18	19	18	17	17	18	4.3
Sodium	max.	mg/l	100	100	110	110	110	110	107	54
Silica	max.	mg/l	20	22	24	27	26	24	24	
Chromium VI	max.	µg/l			0.093			0.19	0.14	4
Vanadium	max.	µg/l	ND	ND	3.3	3.1	3	4.2	<3	3.1
THMs	max.	µg/l	10	12	15	13	20	17	14	12
SAR	max.		4.0	3.8	4.1	4.0	4.2	4.2	4.0	2.0